

Aggregate Grading Report

Test Report on Determination of Particle Size Distribution on Aggregates



BURLINGTON
AGGREGATES

Test No: **GL2020003**
Material: **South Lakes Dove Grey 10mm**
Supplier / Source: **Goldmire Quarry**
Sampled From: **Stockpile**
Material Type: **Dove Grey Limestone**
Specification: **SSD 10mm 4/10**
Method: **BS EN 933-1: 2012**

BS Sieve	Wt Retained (g)	Retained %	Passing %	Specification
20	0	0.0	100	100
14	22	0.8	99	98 - 100
10	350	12.6	87	80 - 99
4	2179	78.4	8	0 - 20
2	85	3.1	5	0 - 5
0.063	75	2.7	2.4	0 - 4

Moisture Content (%)	2.6%
-----------------------------	------

The sample as supplied and tested **COMPLIES with** Specification grading limits

Signed: *T. Coldrick*
Name: **T. Coldrick**

